



China Quality Certification Centre

CERTIFICATE OF CONFORMITY

Certificate No.: CE070305001385

Product

Thermal Overload Relay

Applicant

Zhejiang Zhengjie Industry Electric Co.,Ltd.

Wenzhou Daqiao Industrial Zone, Yueqing, Zhejiang
Province, P.R.China

Type/model

UKH-12M

Technical data

Ue=AC690V;Ie:16-22A,18-26A,24-36A,28-40A;Trip

Class:10A;3P

This is to certify that, on the basis of the tests undertaken as per Report No. C009-CE2007CQC0305-001669, the submitted sample of the above item complies with:

EN60947-4-1:2001

and fulfill testing requirement of the European Directive:

2006/95/EC;2006/95/EC

李怀林

President Li Huailin



Date of issue: Aug.24,2007

Date of expiration: Aug.24,2010



China Quality Certification Centre
Section 9, No.188, Nansihuan Xilu, Beijing
100070 P.R.China

0001055