

## ATTESTATION OF CONFORMITY

Number: 2138134.00A

Issued to: Zhejiang KRIPAL Electric Co., Ltd.  
Wenzhou Daqiao Industrial Zone,  
Beibaixiang, Yueqing, Zhejiang  
China

For the product: Moulded Case Circuit Breaker

Trade name: KRIPAL

Type/Model: UKM32-160

Ratings: 16, 20, 25, 32, 40, 50, 63, 80, 100, 125, 160 A  
Icu = Ics = 42 kA, 3P or 3P+N  
See annex for further ratings

Manufactured by: Zhejiang KRIPAL Electric Co., Ltd.  
Wenzhou Daqiao Industrial Zone,  
Beibaixiang, Yueqing, Zhejiang  
China

Requirements: EN 60947-2:2006, A1:2009, IEC 60947-2:2006, A1:2009

This Attestation is granted on account of an examination by KEMA Quality, the results of which are laid down in a confidential file no. 3300630.50.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by KEMA Quality is not the responsibility of KEMA Quality.

Arnhem, December 23, 2010

KEMA Quality B.V.

H.L. Schendstok

Certification Manager

© Integral publication of this attestation and adjoining reports is allowed