



China Quality Certification Centre

CERTIFICATE OF CONFORMITY

Certificate No.: CE070302001387

Product

Contactor

Applicant

Zhejiang Zhengjie Industry Electric Co.,Ltd.

Wenzhou Daqiao Industrial Zone, Yueqing, Zhejiang
Province, P.R.China

Type/model

UKD1

Technical data

UKD1-12: Ith=50A, AC-3: Ue=AC660V Ie=20A, Ue=AC380V
Ie=12A; UKD1-32: Ith=60A, AC-3: Ue=AC660V
Ie=23A, Ue=AC380V Ie=32A;
Us: AC110V, 220V, 240V, 380V, 415V, 440V; 3P

This is to certify that, on the basis of the tests undertaken as per Report No. C009-CE2007CQC0302-001666, the submitted sample of the above item complies with:

EN60947-4-1:2001

and fulfill testing requirement of the European Directive

2006/95/EC; 2006/95/EC

李怀林

President Li Huailin



China Quality Certification Centre
Section 9, No.188, Nansihuan Xilu, Beijing
100070 P.R.China