



Certificate of Compliance

Certificate: 1287592

Master Contract: 180161 (LR 86957)

Project: 1415274


Date Issued: March 4, 2003


Issued to: **Relpol S.A.**
U1. 11 Listopada 37
68-200 Zary
POLAND

Attention: Mr. Waldemar Loboda

The products listed below are eligible to bear the CSA Mark shown



Issued by: 
M. Mihai, M. Sc.

Authorized by: 
Nick Alfano
Operations Manager

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Relays R2 with suffixes, 2-pole, rated 250 VAC, 10 A, Resistive; 150 VAC, 12A, Resistive; Coil rated 6 through 220 VDC, 6 through 240 VAC, 50/60 Hz;

Relays R3 with suffixes, 3-pole, rated 250 VAC, 6 A, Resistive; 150 VAC, 10A, Resistive; Coil rated 6 through 220 VDC, 6 through 240 VAC, 50/60 Hz;

Relays RM84 with suffixes, 2-pole, rated 250 VAC, 8 A, Resistive; Coil rated 3 through 110 VDC, 24 through 240 VAC, 50/60 Hz;

Relays RM85 with suffixes, 1-pole, rated 250 VAC, 16 A, Resistive; 24V DC, 10A, Resistive; Coil rated 3 through 110 VDC, 24 through 240 VAC, 50/60Hz;

Relays RM85 with suffixes, sensitive version, 1-pole, rated 250 VAC, 10 A, Resistive; 24VDC, 10A, Resistive; Coil rated 6 through 24 VDC

Relays RM87 with suffixes, 1-pole, rated 250 VAC, 12 A, Resistive; Coil rated 3 through 110 VDC, 24 through 240 VAC, 50/60 Hz;

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 14 - Industrial Control Equipment