

## SDM120A

Single Phase Two Wires DIN Rail Energy Meter.One Module

**EASTRON**  
**东鸿科技**



## Safety Instructions

### Information for your own safety

This manual does not contain all of the safety measures for operation of the equipment(module,device),because special operating conditions, and local code requirements or regulations may necessitate further measures. However,it does contain information which must be read for your personal safety and to avoid material damages.This information is highlighted by a warning triangle and is represented as follows, depending on the degree of potential danger.



#### Warning

This means that failure to observe the instruction can result in death, serious injury or considerable material damage.



#### Caution

This means hazard of electric shock and failure to take the necessary safety precautions will result in death,serious injury or considerable material damage.

### Qualified personnel

Operation of the equipment (module, device) described in this manual may only be performed by qualified personnel. Qualified personnel in this manual means person who are authorized to commission, start up, ground and label devices,systems and circuits according to safety and Regulatory standards.

### Use for the intended purpose

The equipment (device, module) may only be used for the application specified in the catalogue and the user manual,and only be connected with devices and components recommended and approved by EASTRON.

### Proper handling

The prerequisites for perfect, reliable operation of the product are proper transport, proper storage, installation and assembly, as well as proper operation and maintenance. When operating electrical equipment, certain parts of this equipment automatically carry dangerous voltages. Improper handling can therefore result in serious injuries or material damage.

- ♦ Use only insulating tools.
- ♦ Do not connect while circuit is live (hot).
- ♦ Place the meter only in dry surroundings.
- ♦ Do not mount the meter in an explosive area or expose the meter to dust, mildew and insects.
- ♦ Make sure the used wires are suitable for the maximum current of this meter.
- ♦ Make sure the AC wires are connected correctly before activating the current/voltage to the meter.
- ♦ Do not connect the meter to a 3 phase - 400VAC - network.
- ♦ Do not touch the meter connecting clamps directly with your bare hands, with metal, blank wire or other material as you may get an electrical shock.
- ♦ Make sure the protection cover is placed after installation.
- ♦ Installation, maintenance and reparation should only be done by qualified personnel.
- ♦ Never break the seals and open the front cover as this might influence the functionality of the meter, and will avoid any warranty.
- ♦ Do not drop, or allow physical impact to the meter as there are high precision components inside that may break.

## Foreword

Thank you for purchasing the EASTRON SDM120 SERIES DIN rail single phase two wires energy meter. With the Eastron product range we have provided a large scale of energy meters on the market suitable for 110V AC to 400V AC (50 or 60Hz). SDM120 series are only 1 module (17.5mm) width, ensuring a high accuracy class (better than Class1), a very low starting current which makes it exceptionally suitable for sub-metering system and general use.

## Technical Data

### Performance criteria

|                                                  |               |
|--------------------------------------------------|---------------|
| Operating humidity                               | ≤ 75%         |
| Storage humidity                                 | ≤ 95%         |
| Operating temperature                            | -20°C - +50°C |
| Storage temperature                              | -30°C - +70°C |
| International standard                           | IEC 62053-21  |
| Accuracy class                                   | 1             |
| Protection against penetration of dust and water | IP51          |
| Insulating encased meter of protective class     | II            |

### Specifications

|                              |                  |
|------------------------------|------------------|
| Nominal voltage(Un)          | 230V             |
| Operational voltage          | 161/279V         |
| Insulation capabilities      |                  |
| - AC voltage withstand       | 4KV for 1 minute |
| - Impulse voltage withstand  | 6KV-1.2μS        |
| Basic current (Ib)           | 5A               |
| Maximum rated current (Imax) | 45A              |
| Operational current range    | 0.4% Ib-Imax     |
| Over current withstand       | 20Imax for 0.01s |
| Operational frequency range  | 50-60Hz          |
| Internal power consumption   | ≤ 2W/10VA/phase  |
| Pulse Output                 | 1000imp/kWh      |

### Basic errors


#### With balanced loads

|                         |       |
|-------------------------|-------|
| 0.05IbCosφ = 1          | ±1.5% |
| 0.1IbCosφ = 0.5L        | ±1.5% |
| Cosφ = 0.8C             | ±1.5% |
| 0.1Ib - ImaxCosφ = 1    | ±1.0% |
| 0.2Ib - ImaxCosφ = 0.5L | ±1.0% |
| Cosφ = 0.8C             | ±1.0% |

#### With single phase load

|                         |       |
|-------------------------|-------|
| 0.1Ib - ImaxCosφ = 1    | ±2.0% |
| 0.2Ib - ImaxCosφ = 0.5L | ±2.0% |

## Dimensions



JIAXING EASTRON ELECTRONIC INSTRUMENTS CO., LTD.

Add: No.1369 Chengnan Road, Nanhu, Jiaxing, Zhejiang, 314001, China

Tel: +86-573-83698881 / 83698882

Fax: +86-573-83698883


Email:sales@eastrongroup.com

Web:www.eastrongroup.com

## Installation

- ◆ We recommend that the connecting wire which is used to connect the meter to the outside circuit should be sized according to local codes and regulations for the capacity of the circuit breaker or over current device used in the circuit.
- ◆ An external switch or a circuit-breaker should be installed on the inlet wire, which will be used as a disconnection device for the meter. And there it is recommended that the switch or circuit-breaker is near the meter so that it is more convenience for the operator. The switch or circuit-breaker should comply with the specifications of the buildings electrical design and all local regulations.
- ◆ The meter has to be installed against a wall which is fire resistant.
- ◆ The meter has to be installed in a good ventilated and dry place.
- ◆ The meter has to be installed in a protection box when placed in dangerous or dusty environment.
- ◆ The meter can be installed and used after being tested and sealed with a letter press printing.
- ◆ The meter can be installed on a 35mm DIN rail or direct on a meter board with screws.
- ◆ The meter should be installed in an available height so that it is easy to read.
- ◆ When the meter is installed in an area with frequent surges due to e.g. thunderstorms, welding machines, inverters etc, protect the meter with Surge Protection Devices.
- ◆ After finishing installation, the meter must be sealed to prevent tampering.
- ◆ Wiring of the wires should be done in accordance with the underneath wiring diagram.

## Wiring Diagram



Terminal 1: L-in  
Terminal 2: L-out  
Terminals 3 & 4: Neutral  
Terminals 6 & 7: Pulse output

## Operation

### Consumption indication

There is a LED on front panel, which flashes when consumption happens. The more quickly LED flashes, the more consumption happens. The constant of the LED is 1000imp/kWh.

### Reading the meter


The SDM120A energy meter is equipped with a 5+1 register. Five integers are marked with black color and one decimal is marked with red. The SDM120D series energy meter is equipped with 6 digits LCD display which is used as recording consumption and can't be reset to zero. Before the accumulated reading go to 10,000kWh, the LCD shows in xxxx.xx (4 integrals+2 decimals). After the reading reaches to 10,000kWh, the LCD shows in xxxxx.x (5 integrals + 1 decimal). The Max. reading is 99999.9kWh.

### Pulse output

SDM120 series DIN rail energy meter is equipped with a pulse output which is fully separated from the inside circuit. That generates pulses in proportion to the measured energy. They are test pulse output (pins 6 & 7). Usually, the test pulse output is used as testing accuracy or reading purpose in close quarters.

The test pulse output is a polarity dependant, passive transistor output requiring an external voltage source for correct operation. For this external voltage source, the voltage ( $U_i$ ) should be 5-27V DC, and the maximum input current ( $I_{max}$ ) should be 27mA DC. To connect the impulse output, connect 5-27V DC to connector 7 (anode), and the signal wire (s) to connector 6 (cathode). The meter pulse is indicated on the front panel.

## Installation Diagram



JIAXING EASTRON ELECTRONIC INSTRUMENTS CO., LTD.

Add: No.1369 Chengnan Road, Nanhu, Jiaxing, Zhejiang, 314001, China

Tel: +86-573-83698881 / 83698882

Fax: +86-573-83698883

Email: sales@eastrongroup.com

Web: www.eastrongroup.com